

JONES TRAIL

Raymond Graham RPE #8409
R. R. #4 TA 4-6841
Bloomington, Indiana

October 17, 1963

Mr. John Stapleton
Bloomington, Indiana

Dear Mr. Stapleton:

I, Raymond Graham, the engineer who designed the West Allen Street sewer line in Bloomington, Indiana from the Illinois Central Railroad track for 1200 feet to the top of the hill am sure this line is adequate for all that area which can be served by gravity type sewers.

This area is severely limited by terrain approximately 1200 feet West along line and no greater than 600 feet North and South at a maximum from the Allen Street line. This line empties into a trunk line that carries not over a fifth of its area as a peak load; therefore, almost unlimited usage of the remaining area involved would not affect either the Allen Street line or the trunk line.

Very truly yours,

Raymond Graham
Raymond Graham, RPE

STATE OF INDIANA

Address Reply to:

Indiana State Board of Health
1330 West Michigan Street
Indianapolis, Indiana
46207



State Board of Health
November 11, 1963

Mr. Robert Jones
1101 W. Allen
Bloomington, Indiana

Dear Mr. Jones:

Re: Southern Hills Mobile Home Park
Bloomington, Monroe County, Indiana

You are hereby notified that the State Board of Health has this 11th day of November, 1963, approved the sanitary features of plans for the above project. The mobile home park will contain space and facilities for fifty (50) independent mobile homes.

The plans were prepared by John T. Stapleton, Professional Engineer, and were presented for approval on October 10, 1963.

This approval is granted with the following conditions:

1. That zoning approval and all local permits have been obtained.
2. That water distribution system shall be separated not less than 10 feet horizontally from a parallel sewer line. The water and sewer connection on each lot shall be separated not less than 5 feet horizontally.
3. That the City of Bloomington agrees to the proposed water and sanitary sewer connection.
4. That the State Board of Health be notified in time to make all necessary inspections.
5. Plans covering the future addition to the park must be submitted to this office for review.

This approval shall be void if construction is not begun before December 1, 1964.

Approval No. G.S. 541

cc: John T. Stapleton, P.E.
Raymond E. Long, City Engineer
Monroe County Health Officer
Chester Canham

Very truly yours,

Robert W. Heider
Division of Sanitary Engineering
Robert W. Heider, Director

81 x 30'

81x30

81 x 30

5th C. I. D. WATER HORN - To the P. & G. F. Horn - in 1818

ALLEN

ST

